



NOTES:

1. Type 'A' curb **REQUIRES PREAPPROVAL** by the City Engineer.
For use **ONLY** when replacing similar curb. This curb is not intended for new construction.
2. Concrete to have compressive strength of 4,000 psi at 28 days.
3. Expansion joints to be provided at each:
 - a. Point of tangency.
 - b. Cold joint.
 - c. Side of inlet structures.
 - d. Side of driveways.
4. Expansion joint material to be pre-molded, asphalt impregnated, non-extruding, with a thickness of 1/2 inch.
5. Contraction joints shall have:
 - a. Spacing of not more than 15 feet.
 - b. Depth of Joint of at least 1½ inches.
6. Base rock 2"-0 or 3/4"-0, 95% (AASHTO T-180) compaction. Base rock shall be to subgrade of street structure or 4 inches, which ever is greater, and shall extend 12 inches behind the curb.
7. Drainage weephole shall be:
 - a. 3 inch I.D. plastic pipe with coupling and beveled outlet end to match face of curb.
 - b. Centered with contraction joints.



City Of Beaverton

PUBLIC WORKS
DEPARTMENT

TYPE 'A' REPLACEMENT
CURB

CITY ENGINEER
Terry Waldele, P.E.

DATE
2 - 07 - 07

DRAWN BY
JR - ED

DRAWING NO.
203