



NOTES:

1. Concrete shall have a minimum compressive strength of 4,000 psi at 28 days. For slump see specifications.
2. Sidewalk panels shall be square with their length equal to the sidewalk's width, except that sidewalks in the Regional Center, Town Center, Station Area and Station Community districts may be wider than 6 feet, in which cases their panels may be 4 to 6 feet square, but all of equal size.
3. Expansion joints to be placed at sides of driveway approaches, utility vaults, sidewalk ramps and/or at points of tangency in curb as shown on the standard drawings for sidewalk ramps and at spacing not to exceed 45 feet.
4. Sidewalk shall have a minimum thickness of 4 inches, except that sidewalk that is intended as a portion of a driveway shall have a minimum thickness of 6 inches. See *Beaverton Standard Dwgs 210 & 211*.
5. Finish with broom and edge all joints.
6. Width of curb is included in planter strip width.
7. Street trees are required except where specifically modified or waived in writing by the City Engineer.
8. For sidewalk repairs, replacements and installations in existing developments, match existing width of sidewalks, and sidewalk panels' widths and lengths.



City Of Beaverton

**PUBLIC WORKS
DEPARTMENT**

STANDARD SIDEWALK

TRAFFIC ENGINEER
Randall R. Wooley

DATE
2-05-07

DRAWN BY
JR - ED

DRAWING NO.
215