

APPENDIX E – Facility Survey Results

The City received detailed results from facility accessibility surveys performed in 2017. As described in the Transition Plan, most of the barriers that were identified through the surveys have been corrected. The remainders are scheduled as listed below. This Appendix will be updated periodically.

Calendar Year 2018 Projects - Complete

Facility name & address	Barriers identified	Remediation	Cost (Est'd)	Responsible Official
Public Works Operations Center 9600 SW Allen Blvd.	<ul style="list-style-type: none"> • Restroom stalls not accessible. • Lacking two ADA accessible parking spaces. 	<ul style="list-style-type: none"> • Remodel restrooms. • Need to add two ADA accessible parking spaces. 	\$7,260 \$ 150	Property and Facilities Manager Public Works Director
Beaverton Library 12375 SW Fifth St.	<ul style="list-style-type: none"> • ADA compliant signs missing. • Brochure holders obstructing aisles. 	<ul style="list-style-type: none"> • Install ADA compliant signs. • Relocate brochure holders 	\$ 150 \$ 150	Library Director Library Director

Calendar Years 2019-2020 Projects

Facility name & address	Barriers	Status	Cost (Est'd)	Responsible Official
Griffith Building 4755 SW Griffith Dr.	<ul style="list-style-type: none"> • Restroom stalls not accessible. 	<i>Work to make customer service</i>	\$18,500	Property and Facilities Manager

Facility name & address	Barriers	Status	Cost (Est'd)	Responsible Official
	<ul style="list-style-type: none"> • Customer service windows at Municipal Court not accessible. • Customer service windows at Police Records not accessible. 	<p><i>windows and restroom stall accessible is expected to be completed over the summer/fall of 2018. No later than 3/31/20.</i></p>	\$12,500	Property and Facilities Manager
Beaverton Library 12375 SW Fifth St.	<ul style="list-style-type: none"> • Seating reserved for wheelchair patrons is less than 5% of total seating. 	<ul style="list-style-type: none"> • Rearrange seating reserved for wheelchair patrons to reach 5% standard (part of seating plan revisions for the entire library). 	\$100 for signage, part of seating redesign master plan project.	Library Director

Calendar Year 2020 Projects

Facility name & address	Barriers	Status	Cost (Est'd)	Responsible Official
Griffith Building 4755 SW Griffith Dr.	<ul style="list-style-type: none">• Customer service windows at Police Records not accessible.	<ul style="list-style-type: none">• Design and build accessible service windows at the new Public Safety Center. Construction to be completed in 2020.	\$35 million (for total facility)	Police Chief